REPLY TO PRE-BID QUERIES FOR THE WORK OF DIVERSION OF EXISITING 1600MM DIA TRUNK SEWER ALONG OUTER RING ROAD HEBBAL PARALLEL TO RAILWAY TRACK

Tender BWSSB/ CE(WWM-WEST)/ACE(WWM-N-W)/DCE(WWM-E&W)/TA-2/839/2023-24 Dt : 01.02.2024
BWSSB/2023-24 /WS/Work_INDENT311

Sl. No	Document Name	Page No/Section Name	Statement	Query	Submitted on	Reply
1.	Bill of Quantities	in BOQ Item 22	For Manufacture of RCC NP3 Class Pipes by using OPC	Whereas it is mentioned as SRC and marked with ISI in Chapter 10 of Section 7 Clause No2 1 1 on page 53 Please clarify	07-02-2024 14:57:02	Tender condition prevails.
2	Cement content	Page 63 Table 4 Section 7	Cement content of concrete is not mentioned	Please clarify	07-02-2024 15:00:01	As per IS Standards.
3	Contract Data	Section 6 Contract D	There is no mobilization Advance	10 Percent Interest Free Mobilization Advance can be considered	07-02-2024 14:52:46	The amounts of the advance payment are: [42] Nature of Advance: 1. Mobilization — Amount (Rs.): 05% of the Contract price — Conditions to be fulfilled: On submission of un-conditional Bank Guarantee. (to be drawn before end of 45 days) Repayment of advance payment for mobilization : [42] The advance loan shall be repaid with percentage deductions from the interim payments certified by the Engineer under the Contract. Deductions shall commence in the 3rd Interim Payment Certificate following that in which the total of all such payments to the Contractor has reached not less than 15 percent of the Contract Price or 3 months from the date of payment. The first instalment of advance has to be recovered within 10 instalments, whichever period concludes earlier, and shall be made at the rate of 7.5 percent of the amounts of all Interim Payment Certificates until such time as the loan has been

						repaid, always provided that the loan shall be completely repaid prior to the expiry of the original time for completion pursuant to Clauses 17 and 26
4	For Relaxation in Tender conditions	Tender document page no 4 to 9	Eligibility criteria have been relaxed for the tenders called by WWM EAST as referenced in indent No BWSSB/2022-23/WS/WORK INDENT/7362 It is clearly stated that the eligibility criteria for 900 mm Dia Rcc pipelines or larger will be the same as those for the 900 mm Dia Rcc pipe line	Requesting for relaxation in the eligibility criteria as 467 Rmt of 900mm Dia RCC Np3 class sewers/16 rmt of 1200 mm dia casing pipe trenchless and 1591cum of RCC M20 grade in lieu of 467 rmt of 1800mm and above The Related documents and query letter have been submitted to your office by hand for further consideration	05-02-2024 01:49:29	Tender condition prevails.
5	Hard Rock	Clause 12 3 On Page 60 of Sec 7	In case of Hard Rock requiring chipping or chiseling measurement shall be taken prior to and after chiseling and the volume of rock excavation shall be measured based on this difference In case of excavation in HR by blasting the quantity of rock excavated shall be stacked along the side of the trench which will be cross checked with the trench dimensions The excavation in rock shall be paid on the stock measurements with a deduction of 40 Percent in volume for voids	However the payment for the rock excavation by blasting shall be limited so as not to exceed the volume computed based on the trench dimensions as per specification in item 12 Please clarify	07-02-2024 15:20:47	Trench measurements will be considered.
6	Hard Rock	Page 45 Clause 12	The Hard Rock obtained during execution will not b	However Rupees 70 per Cubic Meter Plus applicable GST of Hard	07-02-2024 15:09:36	Tender condition prevails.

			auctioned by Board because of restriction in stock of hard rock in site and safety issue	Rock will be recovered from the firm in Running bills Please clarify		
7	Payment	Section 6 Contract Data	There is no payment terms	Payment terms can be considered as After Supply of RCC Pipes 75 Percent After laying and jointing 20 Percent After conduction flow test and commissioning 5 Percent	07-02-2024 14:55:20	**Payment Terms.** The employer will make the payment to the items of pipelines on the following terms-(Clause 43 GCC). 70% of the contract price — After supply of DWC/RCC pipes to site of work 25% of the contract price — After laying of pipes. 05% of the contract price — After Completion and commissioning of Pipeline work including complete restoration.
8	Relaxation for tender conditions	Tender document page no 4 to 9	Dear sir already wwm east in the section relaxation is done reference indent number is BWSSB/2022-23/WS/WORK INDENT 7362 please consider this along with the same conditions /1800mm Dia pipe similar work of value not less than Rs407 69 lakh this condition relaxation for 900mm Dia pipework of value not less than Rs407 69 lakh please consider these conditions	467RMT of 1800mm Dia and above RCC NP 3 class sewers this condition relaxation for 467rmt of 900mm Dia Rcc np 3 class sewers/16RMT of 1200mm Dia ms casing pipe trenchless technology/1591cum of rcc m20 grade or cement concrete work please consider these conditions this condition related documents and letter submitted your office along with hand	03-02-2024 16:15:38	Tender condition prevails.
9	Relaxation for tender conditions	Tender document page no 4 to 9	In East Division the relaxation has given to the work having 1800mm dia by obtaining the work dine certificates of above 900mm dia for the	In East Division the relaxation has given to the work having 1800mm dia by obtaining the work dine certificates of above 900mm dia for the Indent No 7362 Hence I am here	04-02-2024 21:35:46	Tender condition prevails.

			Indent No 7362 Hence I am here by requesting you to consider 800mm dia and above work done certificates to compete the tender If this relaxation is given the department will get less financial burden	by requesting you to consider 800mm dia and above work done certificates to compete the tender If this relaxation is given the department will get less financial burden		
10	Transport	Page 47 Clause 27 3 transport	Requirement of transport vehicle new top end 4 Plus 1 seated AC Maruti Grand Vitara Alpha Plus intelligent fully loaded	For providing vehicle we would like to inform you that recently in Arkavathy Tender the same was included by incorporating to provide the vehicle and the capital cost of the vehicle will be reimbursed at actual cost under provisional sum excluding insurance The same has not been considered in this tender either you consider the same or delete from the contract	07-02-2024 15:05:08	Requirement of transport vehicle new top end 4 Plus 1 seated AC Toyota Glanza fully loaded
11	Unit of Item	BOQ Item 22	Unit is mentioned as Cubic Meter	The same should be RMT Please clarify	07-02-2024 14:59:08	Unit is mtr

Chief Engineer (WWM-west)
BWSSB